

AMENDMENT OF SOLICITATION/MODIFICATION OF CONTRACT

Architect of the Capitol

1. AMENDMENT/MODIFICATION NO. 02	2. EFFECTIVE DATE 11/22/2005	3. REQUISITION/PURCHASE REQ. NO. LC 050193	4A. TITLE: Replace west fire pump JMMB	4B. PROJECT NO.
5. ISSUED BY AOC - Procurement Division 2nd & D Streets, SW Room H2-263 WASHINGTON, DC 20515			6. ADMINISTERED BY (If other than Item 5) ATTN:	
7. NAME AND ADDRESS OF CONTRACTOR (No., street, country, state and ZIP Code)			(X)	8A. AMENDMENT OF SOLICITATION NO. RFP050110
			X	8B. DATED (SEE ITEM 11) 11/01/2005
				9A. MODIFICATION OF CONTRACT/ORDER NO.
				9B. DATED (SEE ITEM 11)

10. THIS ITEM ONLY APPLIES TO AMENDMENTS OF SOLICITATIONS

☒ The above numbered solicitation is amended as set forth in item 13. The hour and date specified for receipt of Offers ☒ is extended, ☐ is not extended,

Offers must acknowledge receipt of this amendment prior to the hour and date specified in the solicitation or as amended, by one of the following methods: (a) By completing items 7 and 14, and returning ___1___ copies of the amendment; (b) By acknowledging receipt of this amendment on each copy of the offer submitted; or (c) By separate letter or telegram which includes a reference to the solicitation and amendment numbers. FAILURE OF YOUR ACKNOWLEDGMENT TO BE RECEIVED AT THE PLACE DESIGNATED FOR THE RECEIPT OF OFFERS PRIOR TO THE HOUR AND DATE SPECIFIED MAY RESULT IN REJECTION OF YOUR OFFER. If by virtue of this amendment your desire to change an offer already submitted, such change may be made by telegram or letter, provided each telegram or letter makes reference to the solicitation and this amendment, and is received prior to the opening hour and date specified.

11. ACCOUNTING AND APPROPRIATION DATA (If required)
SEE LINE ITEMS

12. THIS ITEM ONLY APPLIES TO MODIFICATION OF CONTRACTS/ORDERS.
IT MODIFIES THE CONTRACT/ORDER NO. AS DESCRIBED IN ITEM 13.

CHECK ONE	A. THIS CHANGE ORDER IS ISSUED PURSUANT TO: (Specify authority) THE CHANGES SET FORTH IN ITEM 13 ARE MADE IN THE CONTRACT ORDER NO. IN ITEM 9A.
	B. THE ABOVE NUMBERED CONTRACT/ORDER IS MODIFIED TO REFLECT THE ADMINISTRATIVE CHANGES (such as changes in paying office, appropriation date, etc.) SET FORTH IN ITEM 13, PURSUANT TO THE AUTHORITY OF FAR 43.103(b).
	C. THIS SUPPLEMENTAL AGREEMENT IS ENTERED INTO PURSUANT TO AUTHORITY OF:
	D. OTHER (Specify type of modification and authority)

E. IMPORTANT: Contractor ☐ is not, ☐ is required to sign this document and return _____ copies to the issuing office.

13. DESCRIPTION OF AMENDMENT/MODIFICATION

Amendment 002 is being issued to address questions submitted as of 11/21/05, list site visit attendees, and extend proposal due date to 12/02/05.

Except as provided herein, all terms and conditions of the document referenced in Item 8A or 9A, as heretofore changed, remains unchanged and in full force and effect.

14A. NAME AND TITLE OF SIGNER (Type or print)		15A. NAME AND TITLE OF CONTRACTING OFFICER (Type or print) Nichele C. Robinson CONTRACTING OFFICER	
14B. CONTRACTOR/OFFEROR	14C. DATE SIGNED	15B. UNITED STATES OF AMERICA BY _____ (Signature of the Contracting Officer)	15C. DATE SIGNED

RFP050110

Summary Info Continuation Page

BASE

Number	Commodity Name	Quantity	Unit of Issue	Unit Price (\$)	Total Cost (\$, Inc. disc)
1	REPLACEMENT OF WEST FIRE PUMP: JAMES MADISON BUILDING	Total : 1.00	EA	\$	\$
Description:IN ACCORDANCE WITH THE SCOPE OF WORK IN THE ATTACHED DESCRIPTION/SPECIFICATIONS/WORK STATE- MENT.					
Lump-Sum Price for Base					\$

General Conditions

Supplementary Conditions

Representations & Certifications

Solicitation Conditions

Notes from Site Visit

**RFP NO. 050110
Replacement of West Fire Pump
JMMB Library of Congress**

**PRE-PROPOSAL MEETING
Tuesday, November 08, 2005
2:00 p.m.**

Attendees:

Nichele Robinson, Procurement Division
Tony DiSanto, LOC Superintendent - JMMB

Companies Represented:

See Site Visit List of Attendees

Notes:

1. Contractors were reminded to sign and date their proposals and to submit proposals via FedEx or UPS (no same day service) only.
2. Contractors were informed that only questions submitted and answered in writing should be considered official. Contractors were allowed to ask questions at the meeting but were cautioned that they should submit their questions in writing for the official response.
3. Contractors were informed that an amendment would be issued providing a list of attendees of the conference, answers to questions submitted in writing up to the amendment's release and notes from the conference.
4. Contractors were reminded that as of the date of the conference, the proposal due date remained November 17, 2005 at 1:00pm.

RFP NO. 050110
Replacement of West Fire Pump
JMMB Library of Congress

PRE-PROPOSAL MEETING
Tuesday, November 08, 2005
2:00 p.m.

Jeff Honner
Simplex Grinnell
9585 Snowden River Pkwy.
Columbia, MD
(410) 381-1400
(410) 381-1475 fax

Brent Luers
National Fire Protection
515 Dover Road, Ste. 2600
Rockville, MD 20850
(301) 315-7541
(301) 309-1284 fax

Don Phillips/Ben Pisarcik
M.C. Dean, Inc.
22461 Shaw Road
Dulles, VA 20166
(703) 222-2561
(703) 421-4378 fax

RFP NO. 050110
Replacement of West Fire Pump
JMMB Library of Congress

QUESTIONS AND RESPONSES

Question 1: **Statement of Work, Section C.3.4. (a,b, &c) list the fire pump data points. The net head pressures listed at churn (shut off) and peak loads (150% of rated capacity) are not consistent with N.F.P.A. 20 “Standard for the Installation of Stationary Pumps for Fire Pumps”, 2003 Edition. Please advise.**

Answer 1: The requirements in the Scope of Work are consistent with NFPA 20 (2003 Edition), section 6.2.1 and section 6.2.2. Those NFPA 20 code references are minimum parameters and are not exact data points. Those sections use the terms "not less than" and "shall not exceed". The requirements in the scope of work were chosen because they represent a pump curve similar to the existing East and West pumps (shifted for the appropriate boost pressure using a city water supply). The contractor is encouraged to download the pump curve for the Peerless Model 6AF-15-B pump as referenced on page 1 of the Statement of Work.

Question 2: **Statement of Work, Section C.3.15 indicates that the contractor is to coordinate... drainage of the tank ... During the pre-bid conference Anthony DiSanto indicated that LOC personnel would drain the tank. Please advise who is responsible for training the tank.**

Answer 2: The AOC is responsible for draining the tank. The AOC will drain the tank to the lowest possible level given the existing drain installation. The contractor should expect a possibility that some water is left in the tank and may flow out when the piping is cut back to the tank wall by the contractor. Existing drains in the floor of the pump room should be able to handle this extra water flow without additional equipment.

Question 3: **Statement of Work, Section C.3.16.b indicates that the contractor is to “Demolish existing water tank pipe to the wall of the tank”. Who will be responsible for patching of the brick wall surrounding the tank?**

Answer 3: The AOC will patch the wall and paint the wall prior to the contractor continuing with the installation of the new controller along that wall.